

Туре				Inverter Heat Pump	
Indoor Unit				PEAD-M100JA(L)	
Outdoor Unit				PUHZ-SHW112VHA(-BS)	PUHZ-SHW112YHA(-BS)
Refrigerant				R410A*1	
Power				Outdoor power supply	
Supply	Outdoor (V/Phase/Hz)			VHA:230 / Single / 50, YHA:400 / Three / 50	
Cooling	Capacity	Rated	kW	10.0	10.0
		Min - Max	kW	4.9 - 11.4	4.9 - 11.4
	Total Input	Rated	kW	2.924 (2.904)	2.924 (2.904)
	EER			-	=
	EEL Rank			-	=
	Design Load		kW	10.0	10.0
	Annual Electricity Co	nsumption*2	kWh/a	729 (714)	729 (714)
	SEER*4			4.8 (4.9)	4.8 (4.9)
		Energy Efficiency Class		В	В
Heating (Average Season)	Capacity	Rated	kW	11.2	11.2
		Min - Max	kW	4.5 - 14.0	4.5 - 14.0
	Total Input	Rated	kW	3.103	3.103
	COP			-	=
	EEL Rank			_	=
	Design Load		kW	12.7	12.7
	Declared Capacity	at reference design temperature	kW	11.2	11.2
	,	at bivalent temperature	kW	11.2	11.2
		at operation limit temperature	kW	9.4	9.4
	Back Up Heating Capacity		kW	1.5	1.5
	Annual Electricity Consumption*2		kWh/a	4664	4664
	SCOP*4		IKV VI I/O	3.8	3.8
	Energy Efficiency Class			A	A
Operating	g Current (max)	and gy amoidiney dided	Α	37.7	15.7
Indoor Unit	Input [Cooling / Heatir	ngl Bated	kW	0.25 (0.23) / 0.23	0.25 (0.23) / 0.23
	Operating Current (max)		A	2.65	2.65
	Dimensions	H × W × D	mm	250 - 1400 - 732	250 - 1400 - 732
	Weight		kg	41 (40)	41 (40)
	Air Volume [Lo-Mid-Hi]		m³/min	24.0 - 29.0 - 34.0	24.0 - 29.0 - 34.0
	External Static Pressure		Pa	35 / 50 / 70 / 100 / 150	35 / 50 / 70 / 100 / 150
	Sound Level (SPL) [Lo-Mid-Hi]		dB(A)	29 - 34 - 38	29 - 34 - 38
	Sound Level (PWL)		dB(A)	61	61
	Dimensions   H × W × D		mm	1350 - 950 - 330 (+30)	1350 - 950 - 330 (+30)
Unit	Weight	II X W X B	kg	120	134
	Air Volume	Cooling	m³/min	100.0	100.0
	All volume		m³/min	100.0	100.0
	Sound Level (SPL)	Heating	dB(A)	51	51
	Journa Level (SPL)	Cooling	dB(A)	52	52
	Cound Love I (DIA)	Heating			
	Sound Level (PWL)	Cooling	dB(A)	69	69
	Operating Current (max)		A	35.0	13.0
	Breaker Size	li: :i/o	Α	40	16
Piping	Diameter	Liquid / Gas	mm	9.52 / 15.88	9.52 / 15.88
	Max. Length	Out-In	m	75	75
	Max. Height	Out-In	m	30	30
10 1		Cooling*3	°C	−15 ~ +46	−15 ~ +46
I-CUTUCOTI		Heating	°C	−25 ~ +21	-25 ~ +21

<sup>\*1</sup> Refrigerant Leakage contributes to climate change. Refrigerant with lower global warming potential (GWP) would contribute less to global warming than a refrigerant with higher GWP, if leaked to the atmosphere. This appliance contains a refrigerant fluid with a GWP equal to 1975. This means that if lkg of this refrigerant fluid would be leaked to the atmosphere, the impact on global warming would be 1975 times higher than 1 kg of CO<sub>2</sub>, over a period of 100 years. Never try to interfere with the refrigerant circuit yourself or disassemble the product yourself and always ask a professional.
\*2 Energy consumption based on standard test results. Actual energy consumption will depend on how the appliance is used and where it is located.
\*3 Optional air protection guide is required where ambient temperature is lower than –5°C.
\*4 SEER and SCOP are based on 2009/125/EC:Energy-related Products Directive and Regulation(EU) No206/2012.