

Compact, high-performance indoor and outdoor units with R32 that is low global warming potential compared with the current refrigerant R410A contribute to room comfort and to prevent global warming.




"Rank A++/A+" Energy Savings Achieved for Entire Range of Series







All models in the series, from capacity 25 to 71, have achieved the "Rank A+" for SEER and "Rank A+" for SCOP as energy-savings rating, thanks to Mitsubishi Electric's inverter technologies which are adopted to provide automatic adjustment of operation load according to need.



Simple and Friendly Design

The round front surface provides a simple and friendly impression. And the width of indoor unit is compact, making installation in smaller, tighter spaces possible.



Wi-Fi and System Control

Wi-Fi Interface (Built-in) *Only VGK model

Built-in interface enabling users to control air conditioners and check operating status via devices such as personal computers, tablets and smartphones.


System Control Interface (Optional)

- •Remote on/off operation is possible by input to the connector.
- •Depending on the interface used, connecting a wired remote-control such as the PAR-41MAA is possible.
- •Centralised control is possible when connected to M-NET.
- *Wi-Fi Interface and System Control Interface cannot be used simultaneously.

Air Purifying Filter

29

This filter generates stable antibacterial and deodorising effects. The size of the three-dimensional surface has been increased as well, enlarging the filter capture area. These features give the Air Purifying Filter better dust collection performance than conventional filters. The superior air-cleaning effectiveness raises room comfort yet another level.



Inverter PAM SEER AT AT AT MSZ-HR SERIES Indoor Unit (R32) **Outdoor Unit** Remote Controller <u>(()</u> MUZ-HR35VF MSZ-HR25/35/42/50VF(K) MUZ-HR42/50VF MUZ-HR60/71VF MSZ-HR60/71VF(K) atural AUTO VBlocking Air Purifying Air Purifying MV-Fi I) Auto Piestart Low Temp Cooling Control Control Uniterlace Control Control Uniterlace Control Contro

T				Inverter Heat Pump					
Туре				1107 1007 500			<u> </u>	107110001500	
Indoor Unit			MSZ-HR25VF(K)	MSZ-HR35VF(K)	MSZ-HR42VF(K)	MSZ-HR50VF(K)	MSZ-HR60VF(K)	MSZ-HR71VF(K)	
Outdoor Unit				MUZ-HR25VF	MUZ-HR35VF	MUZ-HR42VF	MUZ-HR50VF	MUZ-HR60VF	MUZ-HR71VF
Refrigerant			R32 ^(r)						
Power Source				Outdoor Power supply					
Supply	Outdoor (V / Phase / Hz)			230V/Single/50Hz					
Cooling	Design load Annual electricity consumption (*2)		kW	2.5	3.4	4.2	5.0	6.1	7.1
		consumption	kWh/a	141	191	226	269	296	355
	SEER (14)			6.2	6.2	6.5	6.5	7.2	7.0
	Energy efficiency class			A++	A++	A++	A++	A++	A++
	Capacity	Rated	kW	2.5	3.4	4.2	5.0	6.1	7.1
		Min-Max	kW	0.5-2.9	0.9-3.4	1.1-4.6	1.3-5.0	1.7-7.1	1.8-7.3
	Total Input	Rated	kW	0.800	1.210	1.340	2.050	1.810	2.330
Heating (Average Season) ^(*5)	Design load		kW	1.9 (-10°C)	2.4 (-10°C)	2.9 (-10°C)	3.8 (-10°C)	4.6 (-10°C)	5.4 (-10°C)
	Declared Capacity	at reference design temperature		1.9 (-10°C)	2.4 (-10°C)	2.9 (-10°C)	3.8 (-10°C)	4.6 (-10°C)	5.4 (-10°C)
		at bivalent temperature	kW	1.9 (-10°C)	2.4 (-10°C)	2.9 (-10°C)	3.8 (-10°C)	4.6 (-10°C)	5.4 (-10°C)
	at operation limit temperature		kW	1.9 (-10°C)	2.4 (-10°C)	2.9 (-10°C)	3.8 (-10°C)	4.6 (-10°C)	5.4 (-10°C)
	Back up heating capacity		kW	0.0 (-10°C)	0.0 (-10°C)	0.0 (-10°C)	0.0 (-10°C)	0.0 (-10°C)	0.0 (-10°C)
	Annual electricity consumption (*2)		kWh/a	614	781	928	1224	1430	1755
	SCOP (4)			4.3	4.3	4.3	4.3	4.5	4.3
	Capacity	Energy efficiency class		A+	A+	A+	A+	A+	A+
		Rated	kW	3.15	3.6	4.7	5.4	6.8	8.1
		Min-Max	kW	0.7-3.5	0.9-3.7	0.9-5.4	1.4-6.5	1.5-8.5	1.5-9.0
	Total Input Rated		kW	0.850	0.975	1.300	1.550	1.810	2.440
Operating Current (Max)		A	5.0	6.7	8.5	10.0	14.1	14.1	
Indoor Unit	Input	Rated	kW	0.020	0.028	0.032	0.039	0.055	0.055
	Operating Curre		A	0.2	0.27	0.3	0.36	0.5	0.5
	Dimensions	H*W*D	mm	280-838-228	280-838-228	280-838-228	280-838-228	305-923-262	305-923-262
	Weight	I	kg	8.5	8.5	9	9	12.5	12.5
	Air Volume (Lo-Mid-Hi-SHi ^(*3))	Cooling	m³/min	3.6 - 5.4 - 7.2 - 9.7	3.6 - 5.6 - 7.8 - 11.7	6.0 - 8.7 - 10.8 - 13.1	6.4 - 9.2 - 11.2 - 13.1	10.4 - 12.6 - 15.4 - 19.6	10.4 - 12.6 - 15.4 - 19.6
		Heating	m³/min	3.3 - 5.4 - 7.4 - 10.1	3.3 - 5.4 - 7.4 - 10.5	5.6 - 7.9 - 10.8 - 13.4	6.1 - 8.3 - 11.2 - 14.5	10.7 - 13.1 - 16.7 - 19.6	10.7 - 13.1 - 16.7 - 19.6
	Sound Level (SPL)	Cooling	dB(A)	21 - 30 - 37 - 43	22 - 31 - 38 - 46	24 - 34 - 39 - 45	28 - 36 - 40 - 45	33 - 38 - 44 - 50	33 - 38 - 44 - 50
	(Lo-Mid-Hi-SHi ^(*3))	Heating	dB(A)	21 - 30 - 37 - 43	21 - 30 - 37 - 44	24 - 32 - 40 - 46	27 - 34 - 41 - 47	33 - 38 - 44 - 50	33 - 38 - 44 - 50
	Sound Level (PWL)	Cooling	dB(A)	57	60	60	60	65	65
Outdoor Unit	Dimensions	H*W*D	mm	538-699-249	538-699-249	550-800-285	550-800-285	714-800-285	714-800-285
	Weight	lo r	kg	23	24	34	35	40	40
	Air Volume	Cooling	m³/min	30.3	32.2	30.4	30.4	42.8	42.8
		Heating	m³/min	30.3	32.2	32.7	32.7	48.3	48.3
	Sound Level (SPL)	Cooling	dB(A)	50	51	50	50	53	53
	Council I amal (District	Heating	dB(A)	50	51	51	51	57	57
	Sound Level (PWL)		dB(A)	63	64	64	64	65	66
	Operating Current (Max)		A	4.8	6.4	8.2	9.6	13.6	13.6
	Breaker Size		Α	10	10	10	12	16	16
Ext. Piping	Diameter	Liquid/Gas	mm	6.35 / 9.52	6.35 / 9.52	6.35 / 9.52	6.35 / 9.52	6.35 / 12.7	6.35 / 12.7
	Max.Length	Out-In	m	20	20	20	20	30	30
	Max.Height	Out-In	m	12	12	12	12	15	15
	ed Operating	Cooling	°C	-10 ~ +46	-10 ~ +46	-10 ~ +46	-10 ~ +46	-10 ~ +46	-10 ~ +46
Range (Outdoor) Heating			℃	-10 ~ +24	-10 ~ +24	-10 ~ +24	-10 ~ +24	-10 ~ +24	-10 ~ +24
(*1) Refriger	ant loakana contribute	es to climate channe. Refrinera	nt with lov	ver global warming notential (G	WP) would contribute less to a	lobal warming than a refrigerant	with higher GWP if leaked to	the atmosphere. This appliance	contains a refrigerant fluid with

⁾ Refrigerant leakage contributes to climate change. Refrigerant with lower global warming potential (GWP) would contribute less to global warming than a refrigerant with higher GWP, if leaked to the atmosphere. This appliance contains a refrigerant fluid with a GWP equal to 550. This means that if 1 kg of CO₂, over a period of 100 years. Never try to interfere with the refrigerant circuity yourself or discassemble the productly curself and always ask a professional.

The GWP of R32 is 675 in the IPCC 4th Assessment Report.

Energy consumption based on standard test results. Actual energy consumption will depend on how the appliance is used and where it is located.

⁽²⁾ Ellegy consumption based on stantage less results. Actual energy consumption will depend on now the applicable sused and where it is located.

(3) SHE Super Hand other related description are based on COMMISSION DELEGATED REGULATION (EU) No.626/2011. The temperature conditions for calculating SCOP are based on "Average Season".

(5) Please see page 53-55 for healing (wation assess) specifications.